
STATUTORY INSTRUMENTS

1989 No. 635

The Electricity at Work Regulations 1989

PART III

REGULATIONS APPLYING TO MINES ONLY

Means of cutting off electricity to circuits below ground

22. At every mine at which electrical equipment which may give rise to danger is installed below ground and is supplied from a power source at the surface of the mine, switchgear shall be provided at the surface for cutting off the supply of current to that equipment, and adequate provision shall be made for the operation of that switchgear, including such means of communication as will, so far as is reasonably practicable, enable the switchgear to be operated in case of danger.