

SCHEDULE 1

Regulations 2, 4, 6, 14, 15, 18, 20 and 22

PRESCRIBED CONCENTRATIONS AND VALUES

Table A Microbiological Parameters

Part 1: Directive requirements				
Item	Parameters	Concentration or Value (maximum)	Units of Measurement	Point of compliance
1	Enterococci	0	number/100 ml	Consumers' taps
2	<i>E.coli</i>	0	number/100 ml	Consumers' taps
Part 2: National requirements				
1	Coliform bacteria	0	number/100 ml	Service reservoirs ⁽¹⁾ and water treatment works
2	<i>E. coli</i>	0	number/100 ml	Service reservoirs and water treatment works

Note:

(1) Compliance required as to 95% of samples from each service reservoir (regulation 4(6)).

Table B Chemical Parameters**Part 1: National requirements**

Item	Parameters	Concentration or Value (maximum)	Units of Measurement	Point of compliance
1	Acrylamide	0.10	µg/l	⁽¹⁾
2	Antimony	5.0	µgSb/l	Consumers' taps
3	Arsenic	10	µgAs/l	Consumers' taps
4	Benzene	1.0	µg/l	Consumers' taps
5	Benzo(a)pyrene	0.010	µg/l	Consumers' taps
6	Boron	1.0	mgB/l	Consumers' taps
7	Bromate	10	µBrO ₃ /l	Consumers' taps
8	Cadmium	5.0	µgCd/l	Consumers' taps
9	Chromium	50	µgCr/l	Consumers' taps
10	Copper	2.0	mgCu/l	Consumers' taps
11	Cyanide	50	µgCN/l	Consumers' taps
12	1, 2 dichloroethane	3.0	µg/l	Consumers' taps

Status: This is the original version (as it was originally made).

13	Epichlorohydrin	0.10	µg/l	(1)
14	Fluoride	1.5	mgF/l	Consumers' taps
15	Lead	10	µgPb/l	Consumers' taps
16	Mercury	1.0	µgPb/l	Consumers' taps
17	Nickel	20	µgNi/l	Consumers' taps
18	Nitrate ⁽²⁾	50	mgNO3/l	Consumers' taps
19	Nitrite ⁽²⁾	0.50	mgNO2/l	Consumers' taps
		0.10		Treatment Works
20	Pesticides ^{(3),(4)}			
	Aldrin	0.030	µg/l	Consumers' taps
	Dieldrin			
	Heptachlor			
	Heptachlor epoxide			
	other pesticides	0.10	µg/l	Consumers' taps
21	Pesticides: Total ⁽⁵⁾	0.50	µg/l	Consumers' taps
22	Polycyclic aromatic hydrocarbons ⁽⁶⁾	0.10	µg/l	Consumers' taps
23	Selenium	10	µgSe/l	Consumers' taps
24	Tetrachloroethene and Trichloroethene ⁽⁷⁾	10	µg/l	Consumers' taps
25	Trihalomethanes: Total ⁽⁸⁾	100	µg/l	Consumers' taps
26	Vinyl chloride	0.50	µg/l	(1)

Notes:

-
- (1) The parametric value refers to the residual monomer concentration in the water as calculated according to specifications of the maximum release from the corresponding polymer in contact with the water. This is controlled by product specification.
 - (2) See also regulation 4(2)(d).
 - (3) See the definition of "pesticides and related products" in regulation 2.
 - (4) The parametric value applies to each individual pesticide.
 - (5) "Pesticides: Total" means the sum of the concentrations of the individual pesticides detected and quantified in the monitoring procedure.
 - (6) The specified compounds are:
 benzo(b)fluoranthene
 benzo(k)fluoranthene
 benzo(ghi)perylene
 indeno(1,2,3-cd)pyrene.
 The parametric value applies to the sum of the concentrations of the individual compounds detected and quantified in the monitoring process.

- (7) The parametric value applies to the sum of the concentrations of the individual compounds detected and quantified in the monitoring process.
- (8) The specified compounds are:
 chloroform
 bromoform
 dibromochloromethane
 bromodichloromethane.
 The parametric value applies to the sum of the concentrations of the individual compounds detected and quantified in the monitoring process.

Part 2: National requirements

Item	Parameters	Concentration or Value (maximum unless otherwise stated)	Units Measurement	Point of compliance
1	Aluminium	200	µgAl/l	Consumers' taps
2	Colour	20	mg/l Pt/Co	Consumers' taps
3	Iron	200	µgFe/l	Consumers' taps
4	Manganese	50	µgMn/l	Consumers' taps
5	Odour	Acceptable to consumers and no abnormal change		Consumers' taps
6	Sodium	200	mgNa/l	Consumers' taps
7	Taste	Acceptable to consumers and no abnormal change	...	Consumers' taps
8	Tetrachloromethane	3	µg/l	Consumers' taps
9	Turbidity	4	NTU	Consumers' taps