Commission Delegated Regulation (EU) No 1292/2014 of 17 July 2014 on the conditions for classification, without testing, of certain uncoated wood floorings under EN 14342 with regard to their reaction to fire (Text with EEA relevance)

COMMISSION DELEGATED REGULATION (EU) No 1292/2014

of 17 July 2014

on the conditions for classification, without testing, of certain uncoated wood floorings under EN 14342 with regard to their reaction to fire

(Text with EEA relevance)

THE EUROPEAN COMMISSION,

Having regard to the Treaty on the Functioning of the European Union,

Having regard to Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonized conditions for the marketing of construction products and repealing Council Directive $89/106/\text{EEC}^{(1)}$, and in particular Article 27(5) thereof,

Whereas:

- (1) A system for classifying the performance of construction products, with regard to their reaction to fire was adopted in Commission Decision 2000/147/EC⁽²⁾. Wood floorings are among the construction products to which that Decision applies.
- (2) Tests have shown wood floorings covered by the harmonised standard EN 14342 to have a stable and predictable performance concerning reaction to fire provided that they meet certain conditions regarding the density of the wood, the thickness of the flooring and the end use of the product.
- (3) Wood floorings covered by the harmonised standard EN 14342 should therefore be deemed to satisfy the classes of performance for reaction to fire established in Decision 2000/147/EC on those conditions without further testing being required,

HAS ADOPTED THIS REGULATION:

Article 1

Wood floorings covered by the harmonised standard EN 14342 which fulfil the conditions set out in the Annex shall be deemed to satisfy the classes of performance indicated in the Annex without testing.

Article 2

This Regulation shall enter into force on the twentieth day following that of its publication in the *Official Journal of the European Union*.

This Regulation shall be binding in its entirety and directly applicable in all Member States.

Changes to legislation: There are outstanding changes not yet made to Commission Delegated Regulation (EU) No 1292/2014. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details) View outstanding changes

Done at Brussels, 17 July 2014.

For the Commission The President José Manuel BARROSO

ANNEX

Product ^{ag}	Product detail ^d	Minimum mean density ^e (kg/ m ³)	Minimum overall thickness(mr	End use condition n)	Class for floorings ^c	
Wood flooring	Solid wood flooring of pine or spruce	Pine: 480 Spruce: 400	14	Without air gap underneath	D _{fl} -s1	
Wood flooring	Solid flooring of beech, oak, pine or spruce	Beech: 700 Oak: 700 Pine: 430 Spruce: 400	20	With or without air gap underneath	D _{fl} -s1	
Wood parquet	Solid wood (one layer) parquet of walnut	650	8	Glued to substrate ^r	D _{fl} -s1	
Wood parquet	Solid (one layer) parquet of oak, maple or ash	Ash: 650 Maple: 650 Oak: 720	8	Glued to substrate ^f	D _{fl} -s1	
Wood parquet	Multilayer parquet with oak top layer, at least 3,5 mm	550	15 ^b	Without air gap underneath	D _{fl} -s1	
Wood flooring and parquet	Solid wood flooring and parquet not specified above	400	6	All	E _{fl}	
	cordance with EN ISC air gap (minimum heig			s2, d0 with minimun	n density of 400 kg/	
	of at least Class E_{fl} and			num density of 280 k	kg/m ³ may be	
c Class as set ou	Class as set out in Table 2 of the Annex to Decision 2000/147/EC.					
d Without surfac	Without surface coatings.					
e Conditioned in	Conditioned in accordance with EN 13238 (50 % RH, 23 °C).					
	Substrate at least Class D-s2, d0.					
g Applies also to	Applies also to steps of stairs.					

Changes to legislation: There are outstanding changes not yet made to Commission Delegated Regulation (EU) No 1292/2014. Any changes that have already been made to the legislation appear in the content and are referenced with annotations. (See end of Document for details) View outstanding changes

(1) OJ L 88, 4.4.2011, p. 5.

(2) Commission Decision 2000/147/EC of 8 February 2000 implementing Council Directive 89/106/ EEC as regards the classification of the reaction to fire performance of construction products (OJ L 50, 23.2.2000, p. 14).

Changes to legislation:

There are outstanding changes not yet made to Commission Delegated Regulation (EU) No 1292/2014. Any changes that have already been made to the legislation appear in the content and are referenced with annotations.

View outstanding changes

Changes and effects yet to be applied to the whole legislation item and associated provisions

Signature modified by S.I. 2019/465 Sch. 3 para. 7