

SCHEDULE 4

UNLOADING OF PETROL AT PETROLEUM FILLING STATIONS AND CERTAIN OTHER PREMISES LICENSED FOR THE KEEPING OF PETROL

PART I

GENERAL REQUIREMENTS

6. In any case where the method of filling the tank is that referred to in paragraph 5, the licensee shall ensure, so far as is practicable, that no filling takes place until—
- (a) the pipe is properly and securely connected to the tank and to the filling point; and
 - (b) (where the pipe is segmented) each segment is properly and securely connected one with another.