

SCHEDULE 2

REPORT ON METER TESTS

1. In respect of each meter to which the report refers, a statement—
 - (a) that the meter referred in the report is accurately described and whether it is a new or repaired meter;
 - (b) that the meter has been examined and tested in accordance with Schedule 1 or one of the equivalent European provisions;
 - (c) that the uncertainty of measurement was not greater than $\pm 0.4\%$ at unity power factor or greater than $\pm 0.6\%$ at 0.5 inductive power factor;
 - (d) that no meter error was greater than any error specified either in the relevant sub-paragraph of paragraph 9 of Schedule 1 or in one of the equivalent European provisions;
 - (e) that the meter did not register when energised on voltage only, whether with or without a current less than the threshold current; and
 - (f) if applicable, as to whether paragraph 1(2) of Schedule 1 did or did not apply (as the case may be).