

SCHEDULE 3

CERTIFICATION TESTS AND TESTING METHODS FOR ALTERNATING CURRENT WATTHOUR METERS

Methods of accuracy test

4. Method A test

4.—(1) A long period dial test where the advance of a kWh display, which is part of or connected to a meter under test, is compared with the advance of a precision kilowatt-hour meter.

Method B test

(2) A short period test where the rate of advance of a meter under test is compared to the rate of advance of a precision kilowatt-hour meter.

Method C

(3) A short period test where the actual rate of advance of a meter, when tested under constant power conditions over a specified test period is compared to the calculated rate of advance for those conditions.