

**Status:** This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

### SCHEDULE 3

#### REQUIREMENTS FOR FUEL OIL STORAGE AREAS

5. Any tap or valve permanently fixed to the tank through which fuel oil can be discharged to the open shall also be within the bund, shall be so arranged as to discharge vertically downwards and shall be shut and locked in that position when not in use.