

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Hot water services

17.—(1) Every unvented water heater, not being an instantaneous water heater with a capacity not greater than 15 litres, and every secondary coil contained in a primary system shall—

- (a) be fitted with a temperature control device and either a temperature relief valve or combined temperature and pressure relief valve; and
- (b) be capable of accommodating expansion within the secondary hot water system.

(2) An expansion valve shall be fitted with provision to ensure that water is discharged in a correct manner in the event of a malfunction of the expansion vessel or system.

Commencement Information

- II** Sch. 2 para. 17 in operation at 3.8.2009, see [reg. 1\(1\)](#)

Changes to legislation:

There are currently no known outstanding effects for the The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, Paragraph 17.