
STATUTORY RULES OF NORTHERN IRELAND

2012 No. 192

The Building Regulations (Northern Ireland) 2012

PART L

Combustion appliances and fuel storage systems

Protection of liquid fuel storage tanks

75. Reasonable provision shall be made to ensure that a liquid fuel storage tank and connecting pipework is so constructed and separated from adjacent buildings and the boundary of the premises as to reduce to a reasonable level the risk of the fuel contained inside it igniting in the event of a fire occurring in adjacent buildings or premises.