
STATUTORY RULES OF NORTHERN IRELAND

2012 No. 381

THE ELECTRICITY SAFETY, QUALITY
AND CONTINUITY REGULATIONS
(NORTHERN IRELAND) 2012

PART 2

PROTECTION AND EARTHING

Electrical protection

6. A generator or distributor shall be responsible for the application of such protective devices to their network as will, so far as is reasonably practicable, prevent any current, including any leakage to earth, from flowing in any part of their network for such a period that that part of their network can no longer carry that current without danger.