

---

STATUTORY RULES OF NORTHERN IRELAND

---

**2012 No. 381**

THE ELECTRICITY SAFETY, QUALITY  
AND CONTINUITY REGULATIONS  
(NORTHERN IRELAND) 2012

PART 2

PROTECTION AND EARTHING

**Continuity of the supply neutral conductor and earthing connections**

7.—(1) A generator or distributor shall, in the design, construction, maintenance or operation of their network, take all reasonable precautions to ensure continuity of the supply neutral conductor.

(2) A generator or distributor shall not introduce or retain any protective device in any supply neutral conductor or any earthing connection of a low voltage network which they own or operate.