

SCHEDULE 3

Monitoring for Group A and Group B Parameters

PART 2

Monitoring for Group B Parameters

Frequency of sampling

4.—(1) Sampling for a Group B parameter must be undertaken at the frequencies specified in Table 4 for those parameters.

TABLE 4

Minimum frequency of sampling for Group B parameters

| <i>Volume m³ /day (calculated as averages taken over a calendar year)</i> | <i>Sampling frequency per year</i> |
|--|--|
| ≤ 1000 | 1 |
| $> 1000 \leq 10,000$ | 1 + 1 for each 3,300 m ³ /day of the total volume (rounding up to the nearest multiple of 3,300 m ³ /day) |
| $> 10,000 \leq 100,000$ | 3 + 1 for each 10,000 m ³ /day of the total volume (rounding up to the nearest multiple of 10,000 m ³ /day) |
| $> 100,000$ | 10 + 1 for each 25,000 m ³ /day of the total volume (rounding up to the nearest multiple of 25,000 m ³ /day) |