
STATUTORY RULES OF NORTHERN IRELAND

2017 No. 212

The Water Supply (Water Quality)
Regulations (Northern Ireland) 2017

PART 5

MONITORING – ADDITIONAL PROVISIONS

Sampling at service reservoirs

16. A water undertaker must take, or cause to be taken, from each of its service reservoirs in each week in which the reservoir is in use, one sample for analysis—

- (a) for testing for compliance with the prescribed concentrations or values in respect of the coliform bacteria and *Escherichia coli* (*E. coli*) parameters;
- (b) for determining the concentration of residual disinfectant; and
- (c) for determining whether the specification in relation to the colony counts parameter is met.