

SCHEDULE 5

BUILDING STANDARDS APPLICABLE TO DESIGN AND CONSTRUCTION

SECTION 3: ENVIRONMENT

Oil storage – protection from spillage

3.24. Every building must be designed and constructed in such a way that an oil storage installation, incorporating oil storage tanks used solely to serve a fixed combustion appliance installation providing space heating or cooking facilities in a building, will–

- (a) reduce the risk of oil escaping from the installation;
- (b) contain any oil spillage likely to contaminate any water supply, groundwater, watercourse, drain or sewer; and
- (c) permit any spill to be disposed of safely.