

SCHEDULE 1

PRESCRIBED CONCENTRATIONS AND VALUES

Table A

Microbiological parameters

Part I: Directive requirements

<i>(1)</i>	<i>(2)</i>	<i>(3)</i>	<i>(4)</i>
<i>Item</i>	<i>Parameters</i>	<i>Concentration or Value (maximum)</i>	<i>Units of Measurement</i>
1.	Enterococci	0	number/100ml
2.	<i>Escherichia coli</i> (<i>E. coli</i>)	0	number/100ml

Part II: National requirements

<i>(1)</i>	<i>(2)</i>	<i>(3)</i>	<i>(4)</i>
<i>Item</i>	<i>Parameters</i>	<i>Concentration or Value (maximum)</i>	<i>Units of Measurement</i>
1.	Coliform bacteria	0	number/100ml