

SCHEDULE 2

PARAMETERS, MONITORING AND SAMPLING FREQUENCIES

Table C

Routine Monitoring: Type B Supplies

10. Turbidity

Notes:

- (i) Samples need not be analysed for nitrate if there are reasonable grounds for believing that nitrate levels in the locality concerned are below 25 mg NO₃/l.
- (ii) Samples should not be assessed qualitatively if there are reasonable grounds for suspecting that the water may give rise to a health hazard.