

**Status:** This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

SCHEDULE 2

Regulations 4 and 7

WATER USAGE

<i>Maximum number of persons to be employed at the building (or the part of it) or, as the case may be, the premises (or the part of them) in question at any point in the connection year</i>	<i>Figure<sup>(1)</sup> for the building (or the part of it) or, as the case may be, the premises (or the part of them) in question with:</i>			
	<i>A toilet but no shower or canteen</i>	<i>A toilet and a shower but no canteen</i>	<i>A toilet and a canteen but no shower</i>	<i>A toilet, a shower and a canteen</i>
0 - 20	56	79	113	135
21 - 50	197	276	394	473
51 - 100	422	591	844	1,013
101 - 200	844	1,181	1,688	2,025
201 - 300	1,406	1,969	2,813	3,375
301 - 400	1,969	2,756	3,938	4,725
401 - 500	2,531	3,544	5,063	6,075
501 - 750	3,516	4,922	7,031	8,438
751 - 1,000	4,922	6,891	9,844	11,813
1,001 - 1,250	6,328	8,859	12,656	15,188
1,251 - 1,500	7,73 <sup>(2)</sup>	10,828 <sup>(2)</sup>	15,469 <sup>(2)</sup>	18,563 <sup>(2)</sup>

(1) The figures given are in cubic metres per annum.

(2) If the number of persons exceeds 1,500, the figure is this value plus the amount in the corresponding column below, plus the same amount for every 250 persons in excess of 1,501—

+1,406	+1,969	+2,813	+3,375
--------	--------	--------	--------