

SCHEDULE 3

MONITORING

PART E

Radioactive substances

Averaging

7. Where the parametric value for radon, tritium or, as the case may be, indicative dose is exceeded in a sample of the water, the Drinking Water Quality Regulator for Scotland must specify, by notice to the enforcing authority, the extent of resampling necessary to ensure that the measured values are representative of an average activity concentration for a full year.