

SCHEDULE 3

MONITORING

PART B

Standard parameters and frequencies

4.—(1) A sample of water must be taken at least annually at a point of compliance for each private water supply system, and analysed for—

- (a) enterococci, *Escherichia coli*, coliform bacteria, colony count 22 °C, colour, turbidity, *Clostridium perfringens* and hydrogen ion concentration (pH);
- (b) copper, iron, lead, manganese, nickel and zinc;
- (c) where the water is supplied to premises within a nitrate vulnerable zone, nitrate; and
- (d) any other parameter, or other micro-organism, parasite or substance, identified (for the time being) as relevant in the monitoring programme in relation to a supply of water—
 - (i) by virtue of regulation 18(2) (as read with regulation 19(2)(a)); or
 - (ii) where relevant, through a risk assessment.

(2) In sub-paragraph (1) “nitrate vulnerable zone” means any area of land designated as a nitrate vulnerable zone by regulation 2 of the Designation of Nitrate Vulnerable Zones (Scotland) Regulations 2015(1).