

## SCHEDULE 3

Regulations 14 to 16

## SAMPLING FREQUENCIES FOR CLASSES A, B, 1 AND 2

Parameter (1)	Sampling Frequency (number per annum) Class A and Class 1			Sampling Frequency (number per annum) Class B and Class 2		
	Reduced	Standard	Increased	Reduced	Standard	Increased
	(2)	(3)	(4)	(5)	(6)	(7)
<b>PART I:</b>						
Conductivity	6	12	24	4	6	12
Hydrogen ion	6	12	24	4	6	12
Odour (qualitative)	6	12	24	4	6	12
Taste (qualitative)	6	12	24	4	6	12
<b>PART II:</b>						
Odour (quantitative)	—	4	24	—	4	12
Taste (quantitative)	—	4	24	—	4	12
Turbidity	—	4	24	—	4	12
Temperature	—	4	24	—	4	12
Nitrate	—	4	24	—	4	12
Nitrite	—	4	24	—	4	12
Ammonium	—	4	24	—	4	12
Iron	—	4	24	—	4	12
Aluminium	—	4	24	—	4	12
Manganese	—	4	24	—	4	12
Colour	—	4	24	—	4	12
<b>PART III:</b>						
Trihalomethanes		4	12	1	4	12
Tetrachloromethanes		4	12	1	4	12
Trichloroethene		4	12	1	4	12
tetrachloroethene		4	12	1	4	12
Copper	1	4	12	1	4	12
Notes:						
(i) Increased or reduced sampling where permitted or required may be confined to the substance in question.						
(ii) The sum of the detected concentrations of fluoranthene, benzo 3.4 fluoranthene, benzo 11.12 fluoranthene, benzo 3.4 pyrene, benzo 1.12 perylene and indeno (1,2,3-cd) pyrene.						

**Status:** This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

Parameter (1)	Sampling Frequency (number per annum) Class A and Class 1			Sampling Frequency (number per annum) Class B and Class 2		
	Reduced	Standard	Increased	Reduced	Standard	Increased
	(2)	(3)	(4)	(5)	(6)	(7)
Lead	1	4	12	1	4	12
Zinc	1	4	12	1	4	12
Pesticides and related products(i)	1	4	12	1	4	12
Polycyclic aromatic hydrocarbons(ii)	1	4	12	1	4	12
<b>PART IV:</b>						
Chloride	—	1	12	—	1	12
Sulphate	—	1	12	—	1	12
Calcium	—	1	12	—	1	12
Magnesium	—	1	12	—	1	12
Sodium	—	1	12	—	1	12
Potassium	—	1	12	—	1	12
Dry residues	—	1	12	—	1	12
Oxidizability (permanganatge value)	—	1	12	—	1	12
Total organic carbon	—	1	12	—	1	12
Boron	—	1	12	—	1	12
Surfactants	—	1	12	—	1	12
Phosphorus	—	1	12	—	1	12
Fluoride	—	1	12	—	1	12
Barium	—	1	12	—	1	12
Silver	—	1	12	—	1	12
Arsenic	—	1	12	—	1	12
Cadmium	—	1	12	—	1	12
Cyanide	—	1	12	—	1	12

Notes:

- (i) Increased or reduced sampling where permitted or required may be confined to the substance in question.
- (ii) The sum of the detected concentrations of fluoranthene, benzo 3.4 fluoranthene, benzo 1.12 fluoranthene, benzo 3.4 pyrene, benzo 1.12 perylene and indeno (1,2,3-cd) pyrene.

**Status:** This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

<i>Parameter</i>	<i>Sampling Frequency (number per annum)</i>			<i>Sampling Frequency (number per annum)</i>		
	<i>Class A and Class 1</i>			<i>Class B and Class 2</i>		
	<i>Reduced</i>	<i>Standard</i>	<i>Increased</i>	<i>Reduced</i>	<i>Standard</i>	<i>Increased</i>
(1)	(2)	(3)	(4)	(5)	(6)	(7)
Chromium	—	1	12	—	1	12
Mercury	—	1	12	—	1	12
Nickel	—	1	12	—	1	12
Antimony	—	1	12	—	1	12
Selenium	—	1	12	—	1	12
Total Hardness	—	1	12	—	1	12
Alkalinity	—	1	12	—	1	12
<b>PART V:</b>						
Total coliforms	—	24	—	—	12	24
Faecal coliforms	—	24	—	—	12	24
Residual disinfectant	—	24	—	—	12	24
Colony counts	—	24	—	—	12	24

Notes:

- (i) Increased or reduced sampling where permitted or required may be confined to the substance in question.
- (ii) The sum of the detected concentrations of fluoranthene, benzo 3.4 fluoranthene, benzo 1.12 fluoranthene, benzo 3.4 pyrene, benzo 1.12 perylene and indeno (1,2,3-cd) pyrene.