

### SCHEDULE 3

Regulation 5(1)(a)

#### REQUIREMENTS FOR FUEL OIL STORAGE AREAS

1. The requirements which have to be satisfied in relation to a fuel oil storage area are as follows.
2. The fuel storage area shall be surrounded by a bund capable of retaining within the area—
  - (a) in a case where there is only one fuel storage tank within the fuel storage area and fuel oil is not otherwise stored there, a volume of fuel oil not less than 110 per cent of the capacity of the tank;
  - (b) in a case where there is more than one fuel storage tank within the fuel storage area and fuel oil is not otherwise stored there, a volume of fuel oil not less than whichever is the greater of—
    - (i) 110 per cent of the capacity of the largest tank within the storage area; and
    - (ii) 25 per cent of the total volume of such oil which could be stored in the tanks within the area;
  - (c) in a case where there is no fuel storage tank within the fuel storage area, a volume of fuel oil not less than 25 per cent of the total of such oil at any time stored within the area;
  - (d) in any other case, a volume of fuel oil not less than any of the following—
    - (i) 110 per cent of the capacity of the fuel storage tank or, as the case may be, of the largest tank within the fuel storage area;
    - (ii) where there is more than one fuel storage tank within the fuel storage area, 25 per cent of the total volume of such oil which could be stored in the tanks within the area;
    - (iii) 25 per cent of the total volume of such oil at any time stored within the area.
3. The bund and the base of the storage area shall be impermeable and shall be designed and constructed so that with proper maintenance they are likely to remain so for a period of at least 20 years.
4. Every part of any fuel storage tank shall be within the bund.
5. Any tap or valve permanently fixed to the tank through which fuel oil can be discharged to the open shall also be within the bund, shall be so arranged as to discharge vertically downwards and shall be shut and locked in that position when not in use.
6. Where fuel from the tank is delivered through a flexible pipe which is permanently attached to the tank—
  - (a) it shall be fitted with a tap or valve at its end which closes automatically when not in use; and
  - (b) it shall be locked in a way which ensures that it is kept within the bund when not in use.
7. No part of the fuel storage area or the bund enclosing it shall be situated within 10 metres of any inland or coastal waters which fuel oil could enter if it were to escape.