

SCHEDULE 3

REQUIREMENTS FOR FUEL OIL STORAGE AREAS

7. No part of the fuel storage area or the bund enclosing it shall be situated within 10 metres of any inland or coastal waters which fuel oil could enter if it were to escape.