

SCHEDULE 1

Regulation 2

CRITERIA FOR CLASSIFICATION OF WATERS

The limits set out below are maxima

No in Annex II to the 1975 Directive	Parameters		DW1	DW2	DW3
2	Colouration (after simple filtration)	mg/l Pt Scale	20 ⁽⁰⁾	100 ⁽⁰⁾	200 ⁽⁰⁾
4	Temperature	°C	25 ⁽⁰⁾	25 ⁽⁰⁾	25 ⁽⁰⁾
7*	Nitrates	mg/l NO ₃	50 ⁽⁰⁾	50 ⁽⁰⁾	50 ⁽⁰⁾
8	Fluorides	mg/l F	1.5		
10*	Dissolved iron	mg/l Fe	0.3	2	
12	Copper	mg/l Cu	0.05 ⁽⁰⁾		
13	Zinc	mg/l Zn	3	5	5
19	Arsenic	mg/l As	0.05	0.05	0.1
20	Cadmium	mg/l Cd	0.005	0.005	0.005
21	Total Chromium	mg/l Cr	0.05	0.05	0.05
22	Lead	mg/l Pb	0.05	0.05	0.05
23	Selenium	mg/l Se	0.01	0.01	0.01
24	Mercury	mg/l Hg	0.001	0.001	0.001
25	Barium	mg/l Ba	0.1	1	1
26	Cyanide	mg/l CN	0.05	0.05	0.05
27	Sulphates	mg/l SO ₄	250	250 ⁽⁰⁾	250 ⁽⁰⁾
31	Phenols (phenol index) paranitroaniline 4- aminoantipyrine	mg/l C ₆ H ₅ OH	0.001	0.005	0.1
32	Dissolved or emulsified hydro carbons (after extraction by petroleum ether)	mg/l	0.05	0.2	1

(0) See regulation 7(1)(b)

* See regulation 7(1)(d)

Status: This is the original version (as it was originally made). This item of legislation is currently only available in its original format.

No in Annex II to the 1975 Directive	Parameters	DW1	DW2	DW3
33	Polycyclic aromatic hydrocarbons	mg/l	0.0002	0.0002
34	Total pesticides (parathion, hexachlorocyclohexane, dieldrin)	mg/l	0.001	0.0025
39	Ammonia	mg/l NH ₄	1.5	4 ⁽⁰⁾

(0) See regulation 7(1)(b)

* See regulation 7(1)(d)