

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Hot water services

24. No supply pipe or secondary circuit shall be permanently connected to a closed circuit for filling a heating system unless it incorporates a backflow prevention device in accordance with a specification approved by the regulator for the purposes of this schedule.