
STATUTORY INSTRUMENTS

2000 No. 128

The Pressure Systems Safety Regulations 2000

PART II

GENERAL

Safe operating limits

7.—(1) The user of an installed system and owner of a mobile system shall not operate the system or allow it to be operated unless he has established the safe operating limits of that system.

(2) The owner of a mobile system shall, if he is not also the user of it—

- (a) supply the user with a written statement specifying the safe operating limits of that system established pursuant to paragraph (1); or
- (b) ensure that the system is legibly and durably marked with such safe operating limits and that the mark is clearly visible.