

SCHEDULE 2

Essential Safety Requirements

PART 6

SPECIFIC QUANTITATIVE REQUIREMENTS FOR CERTAIN PRESSURE EQUIPMENT

Hydrostatic test pressure

40. For pressure vessels, the hydrostatic test pressure referred to in paragraph 27 must be no less than whichever is greater of the following—

- (a) that corresponding to the maximum loading to which the pressure equipment may be subject in service taking into account its maximum allowable pressure and its maximum allowable temperature, multiplied by the coefficient 1.25;
- (b) the maximum allowable pressure multiplied by the coefficient 1.43.

Changes to legislation:

There are currently no known outstanding effects for the The Pressure Equipment (Safety) Regulations 2016, Paragraph 40.