

SCHEDULES

SCHEDULE 2

REQUIREMENTS

PART 1

REQUIREMENTS

Fuel storage

5.—(1) All fuels, oils and other liquids with the potential to contaminate the Order land shall be stored in a secure bonded area in order to prevent any accidental or unauthorised discharge to the ground.

(2) The area for storage shall not drain to any surface water system.

(3) Where it is proposed to store more than 200 litres of any type of oil must be stored in accordance with the provisions of the Control of Pollution (Oil Storage) (England) Regulations 2001⁽¹⁾.

(4) Where a drum or barrel has a capacity less than 200 litres a drip tray capable of retaining 25% of the maximum capacity of the drum or barrel may be used in lieu of storing the drum or barrel in the secure bonded area.

⁽¹⁾ S.I. 2001/2954.