

SCHEDULE 3

REQUIREMENTS FOR FUEL OIL STORAGE AREAS

4. Every part of any fuel storage tank must be within the bund.