

SCHEDULE 1

Concentrations or Values

PART 2

Indicator Parameters

TABLE C:

Prescribed concentrations, values or states

| Parameters | Maximum concentration or value | Units of Measurement |
|---|---|--|
| Ammonium | 0.50 | mg/l |
| Chloride ⁽¹⁾ | 250 | mg/l |
| <i>Clostridium perfringens</i> (including spores) | 0 | Number/100ml |
| Coliform bacteria | 0 | Number/100ml (Number/250ml in the case of water put into bottles or containers) |
| Colony counts | No abnormal change | Number/ml at 22°C |
| Conductivity ⁽¹⁾ | 2500 | µS/cm at 20°C |
| Hydrogen ion | 9.5 (maximum) 6.5 (minimum) (in the case of still water put into bottles or containers the minimum is 4.5) | pH value pH value |
| Sulphate ⁽¹⁾ | 250 | mg/l |
| Total organic carbon (TOC) | No abnormal change | mgC/l |
| Turbidity ⁽²⁾ | 1 | NTU |

(1) The water should not be aggressive.

(2) Only in the case of surface water or groundwater that has been influenced by surface water.