

## SCHEDULE 2

### Monitoring

## PART 2

### Monitoring for Group B parameters

#### Frequency of sampling

4. Sampling for Group B parameters must be carried out at the frequencies specified in Table 3.

**Table 3**

**Sampling frequency for Group B parameters**

<i>Volume m<sup>3</sup>/day</i>	<i>Sampling frequency per year</i>
$\leq 10$	1
$> 10 \leq 3,300$	2
$> 3,300 \leq 6,600$	3
$> 6,600 \leq 100,000$	4
$> 10,000 \leq 100,000$	3 + 1 for each 10,000 m <sup>3</sup> /day of the total volume (rounding up to the nearest multiple of 10,000 m <sup>3</sup> /day)
$> 100,000$	10 + 1 for each 25,000 m <sup>3</sup> /day of the total volume (rounding up to the nearest multiple of 25,000 m <sup>3</sup> /day)