

## SCHEDULE 4

### Monitoring for indicative dose and analytical performance characteristics

#### **Monitoring for compliance with the indicative dose**

1.—(1) A water undertaker may use reliable screening strategies to indicate the presence of radioactivity in water intended for human consumption.

(2) The strategies may include screening for—

- (a) certain radionuclides or individual radionuclide; or
- (b) gross alpha activity or gross beta activity (where appropriate gross beta activity may be replaced by residual beta activity after subtraction of the K-40 activity concentration).