

SCHEDULE 4

Monitoring for indicative dose and analytical performance characteristics

Screening for certain radionuclides, or screening for an individual radionuclide

2.—(1) If one of the activity concentrations exceeds 20% of the corresponding derived value or the tritium concentration exceeds its parametric value listed in Schedule 2 an analysis of additional radionuclides is required.

(2) In deciding which radionuclides are required to be measured for each supply, a water undertaker must take into account all relevant information about likely sources of radioactivity.