

SCHEDULES

FIRST SCHEDULE

PART III

FIRE-RESISTING STORE-ROOMS

- 6 If electric light is used, all conductors and apparatus shall be so constructed, installed, protected, worked and maintained as to prevent danger. Vacuum-type lamps only shall be used, and shall be in fixed positions and fitted with substantial outer protecting globes.

Changes to legislation:

There are currently no known outstanding effects for the Uniformity of Laws Act (Northern Ireland) 1922, Paragraph 6.