

ANNEX II

MINIMUM HEALTH AND SAFETY REQUIREMENTS FOR WORKPLACES ALREADY IN USE, AS REFERRED TO IN ARTICLE 4 OF THE DIRECTIVE

3. Electrical installations

Electrical installations must be designed and constructed so as not to present a fire or explosion hazard; persons must be adequately protected against the risk of accidents caused by direct or indirect contact.

Electrical installations and protection devices must be appropriate to the voltage, external conditions and the competence of persons with access to parts of the installation.