

ANNEX IV

MINIMUM SAFETY AND HEALTH REQUIREMENTS FOR CONSTRUCTION SITES Referred to in Article 9 (a) and Article 10 (1) (a) (i) of the Directive

PART B

SPECIFIC ^{X1}MINIMUM REQUIREMENTS FOR] ON-SITE WORKSTATIONS

Section I

On-site indoor workstations

6. Floors, walls, ceilings and roofs of rooms
 - 6.1. The floors of workplaces must have no dangerous bumps, holes or slopes and must be fixed, stable and not slippery.
 - 6.2. The surfaces of floors, walls and ceilings in rooms must be such that they can be cleaned or refurbished to an appropriate standard of hygiene.
 - 6.3. Transparent or translucent walls, in particular all-glass partitions, in rooms or in the vicinity of workplaces and traffic routes must be clearly indicated and made of safety material or be shielded from such places or traffic routes to prevent workers from coming into contact with walls or being injured should the walls shatter.