

---

**Status:** EU Directives are being published on this site to aid cross referencing from UK legislation. After IP completion day (31 December 2020 11pm) no further amendments will be applied to this version.

---

## ANNEX I

### MINIMUM REQUIREMENTS FOR PARAMETRIC VALUES USED TO ASSESS THE QUALITY OF WATER INTENDED FOR HUMAN CONSUMPTION

#### Part A

#### Microbiological parameters

Parameter	Parametric value	Unit	Notes
Intestinal enterococci	0	number/100 ml	For water put into bottles or containers, the unit is number/250 ml.
<i>Escherichia coli</i> ( <i>E. coli</i> )	0	number/100 ml	For water put into bottles or containers, the unit is number/250 ml.