ANNEX I

MINIMUM REQUIREMENTS FOR PARAMETRIC VALUES USED TO ASSESS THE QUALITY OF WATER INTENDED FOR HUMAN CONSUMPTION

Part B

Chemical parameters

Parameter	Parametric value	Unit	Notes
Acrylamide	0,10	μg/l	The parametric value of 0,10 µg/l refers to the residual monomer concentration in the water as calculated according to specifications of the maximum release from the corresponding polymer in contact with the water.
Antimony	10	μg/l	
Arsenic	10	μg/l	
Benzene	1,0	μg/l	
Benzo(a)pyrene	0,010	μg/l	
Bisphenol A	2,5	μg/l	
Boron	1,5	mg/l	A parametric value of 2,4 mg/l shall be applied when desalinated water is the predominant water source of the supply system concerned or in regions where geological conditions could lead to high levels of boron in groundwater.
Bromate	10	μg/l	
Cadmium	5,0	μg/l	
Chlorate	0,25	mg/l	A parametric value of 0,70 mg/l shall

a Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

			be applied where a disinfection method that generates chlorate, in particular chlorine dioxide, is used for disinfection of water intended for human consumption. Where possible, without compromising disinfection, Member States shall strive for a lower value. This parameter shall be measured only if such disinfection methods
Chlorite	0,25	mg/l	are used. A parametric value of 0,70 mg/l shall be applied where a disinfection method that generates chlorite, in particular chlorine dioxide, is used for disinfection of water intended for human consumption. Where possible, without compromising disinfection, Member States shall strive for a lower value. This parameter shall be measured only if such disinfection methods are used.
Chromium	25	μg/l	The parametric value of 25 µg/l shall be met, at the latest, by 12 January 2036. The parametric value for chromium until that date shall be 50 µg/l.
Copper	2,0	mg/l	
Cyanide	50	μg/l	

Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

1,2-dichloroethane	3,0	μg/l	
Epichlorohydrin	0,10	μg/l	The parametric value of 0,10 µg/l refers to the residual monomer concentration in the water as calculated according to specifications of the maximum release from the corresponding polymer in contact with the water.
Fluoride	1,5	mg/l	
Haloacetic acids (HAAs)	60	μg/l	This parameter shall be measured only when disinfection methods that can generate HAAs are used for the disinfection of water intended for human consumption. It is the sum of the following five representative substances: monochloro-, dichloro-, and trichloro-acetic acid, and mono- and dibromo-acetic acid.
Lead	5	μg/l	The parametric value of 5 µg/l shall be met, at the latest, by 12 January 2036. The parametric value for lead until that date shall be 10 µg/l.
			After that date, the parametric value of 5 µg/l shall be met at least at the point of supply to the domestic distribution system. For the purposes of point (b) of the

Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

			first subparagraph of Article 11(2), the parametric value of 5 µg/l at the tap shall apply.
Mercury	1,0	μg/l	
Microcystin-LR	1,0	μg/l	This parameter shall be measured only in the event of potential blooms in source water (increasing cyanobacterial cell density or bloom forming potential).
Nickel	20	μg/l	
Nitrate	50	mg/l	Member States shall ensure that the condition [nitrate]/50 + [nitrite]/3 \leq 1, where the square brackets signify the concentrations in mg/l for nitrate (NO ₃) and nitrite (NO ₂), is complied with and that the parametric value of 0,10 mg/l for nitrites is complied with ex water treatment works.
Nitrite	0,50	mg/l	Member States shall ensure that the condition [nitrate]/50 + [nitrite]/3 \leq 1, where the square brackets signify the concentrations in mg/l for nitrate (NO ₃) and nitrite (NO ₂), is complied with and that the parametric value of 0,10 mg/l for nitrites is complied with ex water treatment works.

a Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

Pesticides	0,10	μg/l	'Pesticides' means:
			— organic
			insecticides,
			— organic
			herbicides,
			— organic
			fungicides,
			— organic
			nematocides
			— organic
			acaricides,
			— organic
			algicides,
			— organic
			rodenticides
			— organic
			slimicides,
			— related
			products
			(inter alia,
			growth
			regulators),
			and their metabolites
			as defined in point
			(32) of Article 3 of
			Regulation (EC) No
			1107/2009 of the
			European Parliament
			and of the Council ^a ,
			that are considered
			relevant for water
			intended for human
			consumption.
			A pesticide
			metabolite shall be
			deemed relevant for water intended for
			human consumption if there is reason to
			consider that it has
			intrinsic properties
			comparable to
			those of the parent
			substance in terms
			of its pesticide
			target activity or
			that either itself or
			its transformation
	1		

a Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

			a health risk for consumers.
			The parametric value of 0,10 µg/l shall apply to each individual pesticide. In the case of aldrin, dieldrin, heptachlor and heptachlor epoxide, the parametric value shall be 0,030 µg/l. Member States shall define a guidance value to manage the presence of nonrelevant metabolites of pesticides in water intended for human consumption. Only pesticides which are likely to be present in a given supply need to be monitored. Based on the data reported by Member States, the Commission may establish a database of pesticides and their relevant metabolites taking into account their possible presence in water intended for human consumption.
Pesticides Total	0,50	μg/l	'Pesticides Total' means the sum of all individual pesticides, as defined in the previous row, detected and quantified in the monitoring procedure.
PFAS Total	0,50	μg/l	'PFAS Total' means the totality of per-

Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

			and polyfluoroalkyl substances. This parametric value shall only apply once technical guidelines for monitoring this parameter are developed in accordance with Article 13(7). Member States may then decide to use either one or both of the parameters 'PFAS Total' or 'Sum of PFAS'.
Sum of PFAS	0,10	μg/l	'Sum of PFAS' means the sum of per- and polyfluoroalkyl substances considered a concern as regards water intended for human consumption listed in point 3 of Part B of Annex III. This is a subset of 'PFAS Total' substances that contain a perfluoroalkyl moiety with three or more carbons (i.e. − CnF2n−, n ≥ 3) or a perfluoroalkylether moiety with two or more carbons (i.e. − CnF2nOCmF2m−, n and m ≥ 1).
Polycyclic aromatic hydrocarbons	0,10	μg/l	Sum of concentrations of the following specified compounds: benzo(b)fluoranthene, benzo(ghi)perylene, and indeno(1,2,3-cd)pyrene.

a Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).

Selenium	20	μg/l	A parametric value of 30 µg/l shall be applied for regions where geological conditions could lead to high levels of selenium in groundwater.
Tetrachloroethene and Trichloroethene	10	μg/l	The sum of concentrations of these two parameters.
Trihalomethanes Total	100	μg/l	Where possible, without compromising disinfection, Member States shall strive for a lower parametric value. It is the sum of concentrations of the following specified compounds: chloroform, bromoform, dibromochloromethane and bromodichloromethane.
Uranium	30	μg/l	
Vinyl chloride	0,50	μg/l	The parametric value of 0,50 µg/l refers to the residual monomer concentration in the water as calculated according to specifications of the maximum release from the corresponding polymer in contact with the water.

a Regulation (EC) No 1107/2009 of the European Parliament and of the Council of 21 October 2009 concerning the placing of plant protection products on the market and repealing Council Directives 79/117/EEC and 91/414/EEC (OJ L 309, 24.11.2009, p. 1).