

ANNEX I

BASIC REQUIREMENTS FOR CONSTRUCTION WORKS

2. Safety in case of fire

The construction works must be designed and built in such a way that in the event of an outbreak of fire:

- (a) the load-bearing capacity of the construction can be assumed for a specific period of time;
- (b) the generation and spread of fire and smoke within the construction works are limited;
- (c) the spread of fire to neighbouring construction works is limited;
- (d) occupants can leave the construction works or be rescued by other means;
- (e) the safety of rescue teams is taken into consideration.

Changes to legislation:

There are currently no known outstanding effects for the Regulation (EU) No 305/2011 of the European Parliament and of the Council, Division 2..