

---

STATUTORY RULES OF NORTHERN IRELAND

---

**2012 No. 381**

THE ELECTRICITY SAFETY, QUALITY  
AND CONTINUITY REGULATIONS  
(NORTHERN IRELAND) 2012

PART 1

INTRODUCTION

**Inspection of networks**

5. A generator or distributor shall, so far as is reasonably practicable, inspect their network with sufficient frequency so that they are aware of what action they need to take so as to ensure compliance with these Regulations and, in the case of their substations and overhead lines, shall maintain for a period of not less than 10 years a record of such an inspection including any recommendations arising therefrom.