
DRAFT SCOTTISH STATUTORY INSTRUMENTS

2014 No.

The Public Water Supplies (Scotland) Regulations 2014

PART 4

MONITORING OF PUBLIC WATER SUPPLIES

Sampling at service reservoirs

12. Scottish Water must take, or cause to be taken, from each of its service reservoirs in each week in which the service reservoir is in use, one sample for analysis—

- (a) for determining the concentration of residual disinfectant;
- (b) for testing for compliance with the prescribed concentration and value for—
 - (i) coliform bacteria (item 3) in Table A; and
 - (ii) *Escherichia coli* (item 4) in Table A; and
- (c) for determining whether the prescribed concentration or value for colony count (item 5) in Table C (in so far as the point of monitoring is a service reservoir) is complied with.