
DRAFT SCOTTISH STATUTORY INSTRUMENTS

2014 No.

The Public Water Supplies (Scotland) Regulations 2014

PART 4

MONITORING OF PUBLIC WATER SUPPLIES

Sampling: water supplied by tanker

13.—(1) Where the distribution of water in any part of a water supply zone is by tanker and is (or is likely to be) an intermittent short-term supply, samples of water from each tanker from which the water is distributed must be taken—

- (a) 48 hours after the commencement of the distribution from that tanker; and
- (b) every 48 hours thereafter until the distribution is discontinued.

(2) The first sample taken in relation to each distribution must be analysed for compliance with—

- (a) *Escherichia coli* (item 2) in Table A;
- (b) conductivity (item 7) in Table C; and
- (c) hydrogen ion (item 8) in Table C.

(3) The second and any subsequent samples must be analysed for compliance with every parameter in Table A, Table B and Table C.