

SCHEDULE 3

REQUIREMENTS FOR FUEL OIL STORAGE AREAS

6. Where fuel from the tank is discharged through a flexible pipe which is permanently attached to the tank–

- (a) it shall be fitted with a tap or valve at its end which closes automatically when not in use;
and
- (b) it shall be kept locked in a way which ensures that it is kept within the bund when not in use.