

SCHEDULE 3

Mandatory licence conditions

Fire safety

3. The holder of the licence must ensure the premises has satisfactory equipment installed for detecting, and for giving warning of—

- (a) fire or suspected fire, and
- (b) the presence of carbon monoxide in a concentration that is hazardous to health.