SCHEDULE 3

PART I

REQUIREMENTS FOR DISCHARGES FROM TREATMENT PLANTS

- 1. Treatment plants shall be designed or modified so that representative samples of the incoming waste water and of treated effluent can be obtained before discharge to receiving waters.
- **2.** Discharges from urban waste water treatment plants subject to treatment in accordance with regulation 5(1) and (2) shall, subject to paragraphs 4 and 5 of Part II of this Schedule, meet the requirements shown in Table 1 below.
- **3.** Discharges from urban waste water treatment plants to those sensitive areas which are subject to eutrophication as identified in sub-paragraph (a) of Part I of Schedule 1 shall, subject to paragraphs 4 and 5 of Part II of this Schedule, also meet the requirements in Table 2 below.
- **4.** More stringent requirements than those shown in Table 1 and/or Table 2 shall be applied where required to ensure that the receiving waters satisfy any other relevant Community Directives.
- 5. The points of discharge of urban waste water shall be chosen, as far as possible, so as to minimise the effects on receiving waters.