

SCHEDULE 3

REQUIREMENTS FOR EMERGENCY SHUT-DOWN VALVES ON CERTAIN MAJOR ACCIDENT HAZARD PIPELINES CONNECTED TO OFFSHORE INSTALLATIONS

1. An emergency shut-down valve shall be incorporated in the riser of a pipeline—
 - (a) in a position in which it can be safely inspected, maintained and tested; and
 - (b) so far as this is consistent with sub-paragraph (a), as far down the riser as is reasonably practicable;

and such valve shall comply with the remaining paragraphs of this Schedule.