
STATUTORY INSTRUMENTS

1998 No. 2451

The Gas Safety (Installation and Use) Regulations 1998

PART F

MAINTENANCE

[^{F1}Determination of date when next safety check due under regulation 36(3)]

36A.—(1) Where a safety check of an appliance or a flue made in accordance with regulation 36(3)(a) or (b) is or was completed within the period of 2 months ending with the deadline date, that check is to be treated for the purposes of regulation 36(3)(a) and (b) as having been made on the deadline date.

(2) Subject to paragraph (3), the landlord may ensure that an appliance or flue is checked for safety within the 2 month period beginning with the deadline date, instead of checking it within the 12 month period ending with that date.

(3) The discretion conferred by paragraph (2) may be exercised—

- (a) only once in relation to each appliance or flue in the relevant premises; and
- (b) only in order to align the deadline date in relation to the next safety check of that appliance or flue with the deadline date in relation to the next safety check of any other appliance or flue in the same relevant premises.

(4) In this regulation “the deadline date”, in relation to a safety check for an appliance or flue, means the last day of the 12 month period within which the check is or was required to be made under regulation 36(3)(a) or (b).]

F1 [Reg. 36A inserted \(6.4.2018\) by The Gas Safety \(Installation and Use\) \(Amendment\) Regulations 2018 \(S.I. 2018/139\), regs. 1, 6](#)

Changes to legislation:

There are currently no known outstanding effects for the The Gas Safety (Installation and Use) Regulations 1998, Section 36A.