

SCHEDULE 2

REQUIREMENTS FOR WATER FITTINGS

Hot water services

18. Appropriate vent pipes, temperature control devices and combined temperature pressure and relief valves shall be provided to prevent the temperature of the water within a secondary hot water system from exceeding 100°C.