

---

STATUTORY INSTRUMENTS

---

**2000 No. 3184**

**The Water Supply (Water Quality) Regulations 2000**

**PART V**

**MONITORING—ADDITIONAL PROVISIONS**

**Sampling at service reservoirs**

**14.** A water undertaker shall take, or cause to be taken, from each of its service reservoirs in each week in which the reservoir is in use, one sample for analysis—

- (a) for testing for compliance with the prescribed concentrations or values in respect of the parameters *E. coli* and coliform bacteria;
- (b) for determining the concentration of residual disinfectant; and
- (c) for determining whether the specification in relation to the colony counts parameter is met.