
STATUTORY INSTRUMENTS

2001 No. 2954

**The Control of Pollution (Oil
Storage) (England) Regulations 2001**

Mobile bowzers

- 5.—(1) Any mobile bowser used for storing oil shall satisfy the following requirements.
- (2) Any tap or valve permanently fixed to the unit through which oil can be discharged to the open must be fitted with a lock and locked shut when not in use.
- (3) Where oil is delivered through a flexible pipe which is permanently attached to the unit—
- (a) the pipe must be fitted with a manually operated pump or with a valve at the delivery end which closes automatically when not in use;
 - (b) the pump or valve must be provided with a lock and locked shut when not in use;
 - (c) the pipe must be fitted with a lockable valve at the end where it leaves the container and must be locked shut when not in use.

Changes to legislation:

There are currently no known outstanding effects for the The Control of Pollution (Oil Storage) (England) Regulations 2001, Section 5.