

SCHEDULE 1

Safety Requirements

Requirement for an isolation valve

7. A manually operated isolation valve must be fitted as close as is reasonably practicable upstream of each acetylene burner or acetylene-consuming equipment.